

**Parkwide Unit Pavement Restoration
Request for Proposals (RFP)
Project/Contract #M4979
Questions & Answers
May 7, 2019**

1. Q: Is there any updated information regarding the number "sites" and/or the approximate SF quantities of the intended scope of work at each location in this contract?

A: No, although as noted in section 01100, no mobilization will be for less than \$35,000 of work.

2. Q: Will each work location have one pavement type or multiple types?

A: It is not possible to give a definitive answer, as the scope will be determined based on the parkwide visual survey conducted with the construction manager. However, it is likely that more than one paver type would be part of a work order as there are numerous conditions where paver types abut.

3. Q: Will "mock ups" be required for existing material being reset or just for the new materials?

A: Materials mock-ups will only be required for new stone.

4. Q: Detail A - Appendix B-1 shows a 1-1/2" mortar setting bed without any reinforcement, however note 2.9 in section 02780 of the specifications states galvanized reinforcing mesh is to be used. Please clarify which is correct.

A: Section 02780 – Unit Pavers includes information pertaining to the setting bed for stone. As referenced in the RFI, note 2.9 in section 02780 includes a directive to use galvanized reinforcing mesh as part of the setting bed for stone. While Detail A in Appendix B-1 does not reference the galvanized reinforcing mesh specifically, the mesh should be included, and applied as directed in section 04852, Installation, sub-section B-5. Galvanized reinforcing mesh is an integral part of the existing mortar setting bed that is to be removed and replaced as illustrated in Detail A.

5. Q: What is the size of the esplanade bluestone?

A: There are multiple sizes throughout the park, which is why the unit price is per square foot.

6. Q: Please advise when bid documents will be available for this project? When is bid walkthru?

A: The documents were posted on the HRPT website, <https://hudsonriverpark.org/about-us/bids-business-opportunities> , on April 23, 2019.

There is no walkthrough for this RFP.

7. Q: We wanted to know the scope of work for the paving. How large is the project in total, what type of pavers, what type of labor etc.

A: Please see Appendix B of the RFP, available as noted in the response to question 5, above.

8. Q: Is this available on line for download or does it have to be picked up?

A: Please see response to question 5, above.

9. Q: Please inform us of any site visits, or pre-bid meetings.

A: There is no pre-bid meeting/site visit. Please be reminded that other relevant dates for this RFP have been modified as noted in the Notice section of this Q&A.